

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20204751  
Address: 2017 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Deck Final Inspection - Residential</b>	Michael Harkins	Failed	Tuesday, August 24, 2021

Corrective Action Required:

1	Miscellaneous Correction	<b>**8-23-21</b> -Deck incomplete -Piers not poured, not inspected and full of water -This inspection will be performed at occupancy  : 8/24/21: NO DECK PIER INSPECTION ON RECORD CITY APPROVED PLANS SHOW COVERED DECK ONLY OPEN DECK WITH STAIRWAY HAS BEEN ADDED TO COVERED DECK THIS IS NOT ON PLANS COVERED DECK PIERS NOT PER PLAN DETAIL K (1) 24 X 36 WITH (4) # 4 VERTICAL BARS DETAIL H (2) 18 X 36 WITH (4) # 4 VERTICAL BARS PROVIDE DETAILS FOR UNCOVERED DECK & STAIRS
---	--------------------------	---

**Comments:**