

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210882
Address: 202 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Wednesday, August 25, 2021

Informational:

1	Misc	GARAGE PFH PORTAL FRAME ONLY APPROVED OK TO COVER
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	Nail exterior wall sheathing per code Seal fire blocking vertical to horizontal at basement furr out Address bore within 2" of bottom of joist rec room Address 6 x 6 deck post not continuous as plan calls for Provide flashing above horizontal window trim
---	--------------------------	--

Comments: