

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200317
Address: 1904 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Wednesday, August 25, 2021

Corrective Action Required:

1	Misc	-Final grade and sod -Restore erosion control at front of lot until sod is in place -GFCI at master bathroom toilet room won't reset -GFCI at dishwasher won't trip -Install light fixtures above kitchen sink -Receptacle at sink in garage required to be GFCI -Receptacle at wet bar within 6' of sink required to be GFCI -Set attic access panel -Complete exterior drain tile -Water meter required to be at 14" to 18" to top of meter can
---	------	--

Comments: