

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20210744  
Address: 2155 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, August 25, 2021

Corrective Action Required:

1	Misc	: GARAGE PORTAL FRAME ONLY : 3" O.C. NAILING PATTERN & HOLD DOWN NAILING APPROVED OK TO COVER
---	------	--

CHECK BELOW ON ROUGH IN  
PROVIDE HEADER TO JACK STUD TENSION STRAPS  
ADDRESS OVER NOTCHED STUDS @ 5/8 ANCHOR BOLTS

Corrective Action Required:

2	Miscellaneous Correction	No Deck pier inspection post not centered on piers Provide CS-PF nailing pattern per plan SGD @ deck Provide double rafters each end of deck fireplace per plan Plans show full height post center of covered deck Fire block bump out dining room Address rafters landing on multiple blocks Shield box in air plenum office Fire block soffit at patio door Seal fire blocking dead spaces family room Fire blocking corner bed #3 Provide boca plate bed #4 closet
---	-----------------------------	---

**Comments:**