

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212468
Address: 4729 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Wednesday, August 25, 2021

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. FAILURE TO CORRECT EROSION CONTROL MAY RESULT IN ISSUANCE OF A STOP-WORK ORDER
		**PROVIDE MIN 3/4" GRAVEL AT LOT ENTRANCE AND REPAIR THE SILT FENCE AT BACK OF LOT

Comments: