

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213683
Address: 4816 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Nick Lightner	Failed	Wednesday, August 25, 2021

Corrective Action Required:

1	Misc	8/19/21 NL - Silt fence closes to the street needs to be repaired. Due to it being on the ground silt has now entered the street.
---	------	---

Corrective Action Required:

2	Misc	8/25/21 NL - Silt fence closes to the street needs to be repaired. Due to it being on the ground silt has now entered the street. Clean up rock and silt in the street, will check back in a week.
---	------	--

Comments: