

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20212200  
**Address:** 4724 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Nick Lightner	Failed - Stop Work	Wednesday, August 25, 2021

**Corrective Action Required**

1	Miscellaneous Correction	-Restore silt fence at perimeter and storm inlet -Clean debris from storm inlet
---	--------------------------	--

**Corrective Action Required**

2	Misc	8/19/21 NL - Restore silt fence at the front of the lot and clean up the silt on the NE corner of the property. Silt fence needs to be installed in the rear of the lot, original silt fence has been taken over by silt runoff. Due to no fence in the rear shutting down future inspections till items have been corrected.
---	------	---

**Corrective Action Required**

3	Misc	8/25/21 NL - Restore silt fence at the front of the lot and clean up the silt on the NE corner of the property. Silt fence needs to be installed in the rear of the lot, original silt fence has been taken over by silt runoff. Due to no fence in the rear shutting down future inspections till items have been corrected.
---	------	---

**Comments:**