



August 25, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Deck beam to deck post connection for Lot #34 Hawthorne Ridge – 1508 Sugar Tree Lee's Summit, MO 64082 – Permit # PRRES20204436

This letter addresses the deck beam and deck post connection for Lot #34 Hawthorne Ridge.

(2) #2 2x12 Deck beam:

- Shall be attached with (2) 5/16" diameter through bolts with nut and washer on continuous post.
- Install (2) bolts per connection.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

