

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213799
Address: 940 NW PRYOR RD, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Thursday, August 26, 2021

Corrective Action Required:

1	Misc	Provide midpoint support vertical 2" & smaller DWV Provide redundant grounding (green mc cable) in patient treatment area Fire caulk floor penetrations
---	------	---

Comments: