

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20203786
Address: 153 NW CARSON DR, LEES SUMMIT, MO 64081
Inspected On: Thursday, August 26, 2021
Inspected By: Robb Popp
Expiration Date: 9/23/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Temporary C of O	Thursday, August 26, 2021

Corrective Action Required:

1	Misc	TCO until 9-23-21
---	------	-------------------

- Maintain erosion control at perimeter until sod is installed
- As graded plot plan required
- Final grade and sod
- Obtain lawn sprinkler permit and backflow certification
- Ensure sewer tracer wire and port are accessible and located at grade level