

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20200866  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Air Test</b>	Nick Lightner	Passed	Thursday, August 26, 2021

Informational:

1 Misc

Line between MH 4-C4 to MH 4-C3 4psi for 2 min= PASS, line between MH 4-C3 to MH 4-C2 4psi for 2 min= PASS, line between MH 4-C2 to MH 4-C1 4psi for 2 min= PASS, MH 4-C1 to MH 4-A2 4psi for 2 min= PASS, MH 4-A2 to MH 4-B1 4 psi for 2 min = PASS, line between MH 4-A2 to MH 4-A1 4 psi for 2 min = PASS, line between MH 4-A2 to MH 4-A3 = FAIL ( Retested 8/26/21 after finding rock between the service lines retest and it PASSED), line between MH 4-A3 to MH 4-A4 4 psi for 2 min = PASS, line between MH 4-A4 to MH 4-A5 4 psi for 2 min = PASS, line between MH 4-A5 to MH 4-D1 4 psi for 2 min = PASS, line between MH 4-D1 TO MH 4-D2 4 psi for 2 min = PASS, line between MH 4-D2 to MH 4-D3 4 psi for 2 min = PASS, line between MH4-A5 to MH4-A6 4 psi for 2 min = PASS, line between MH 4-A6 to MH 4-A7 4 psi for 2 min = PASS, line between MH 4-A7 to MH 4-A8 4 psi 2 min = PASS, MH 4-A8 to MH 4-A9 4 psi for 2 min = PASS

**Comments:**