

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20200866  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Nick Lightner	Passed	Thursday, August 26, 2021

Informational:

1	Misc	MH 4-C4 10 psi 4 min= PASS, MH 4-C3 10 psi 4 min= PASS, MH 4-C2 10 psi 4 min= PASS, MH 4-C1 10 psi 4 min=PASS, MH 4-A2 = FAIL ( Retested 8/26/21 PASSED ), MH 4-B1 10 psi 4 min = PASS, MH 4-A1 10 psi 4 min = PASS, MH 4-A3 10 psi 4 min = PASS, MH 4-A4 10 psi 4 min = FAIL ( Retest 8/25/21 PASSED ), MH 4-A5 10 psi 4 min = PASS, MH 4-D1 10 psi 4 min = PASS, MH 4-D2 10 psi 4 min = PASS, MH 4-D3 10 psi 4 min = PASS, MH 4-A6 10 psi 4 min = PASS, MH 4-A7 10 psi 4 min = PASS, MH 4-A8 10 psi 4 min = PASS, MH 4-A9 10 psi 4 min = PASS
---	------	---

**Comments:**