

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20212678

Address: 32 SE 3RD ST, LEES SUMMIT, MO 64063224 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Failed	Thursday, August 26, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide boca plate DWV Fire caulk upward penetrations Provide midpoint support vertical DWV 2" & smaller
---	-----------------------------	--

**Comments:**