

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210882  
Address: 202 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Thursday, August 26, 2021

Informational:

1	Misc	GARAGE PFH PORTAL FRAME ONLY APPROVED OK TO COVER
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	Address 6 x 6 deck post not continuous as plan calls for Provide flashing above horizontal window trim OK TO INSULATE
---	-----------------------------	---

**Comments:**