

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211961
Address: 1523 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Thursday, August 26, 2021

Corrective Action Required:

1	Misc	EROSION CONTROL REQUIRED AT FRONT OF LOT REPAIR DAMAGED SILT FENCE ON WEST SIDE PROPERTY LINE CLEAN ALL MUD BUILT UP AT GUTTER BUDDY AT STORM INLET AT FRONT OF LOT, CLEAN ANY MUD FROM STREET GRAVEL FILTER AT DRIVE, 4" LIFT REQUIRED
---	------	--

Comments: