

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212068
Address: 3213 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Michael Harkins	Not Ready	Friday, August 27, 2021

Corrective Action Required:
1 Misc -PROVIDE FULL GRAVEL SUPPORT FOR PLUMBING
Corrective Action Required:
2 Miscellaneous PROVIDE GRAVEL BED FOR UNDERSLAB PLUMBING
Correction 2018 IRC P2604.1

Comments: