

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212683  
Address: 1033 SW REDBUCK CIR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                        | Inspector:      | Outcome: | Date:                   |
|----------------------------------------------------|-----------------|----------|-------------------------|
| <b>Underslab Plumbing Inspection - Residential</b> | Michael Harkins | Passed   | Friday, August 27, 2021 |

Corrective Action Required:  
1      Misc      POST ADDRESS

**Comments:**