

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210948  
Address: 306 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:     | Outcome: | Date:                   |
|----------------------------|----------------|----------|-------------------------|
| <b>Driveway Inspection</b> | Ronald Paynter | Partial  | Friday, August 27, 2021 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | Forms were placed and aggregate was present and compacted. Curbing is busted up and needs 2 panels removed and replaced. RP 8-23-21 |
|---|------|---|

Informational:

|   |      |  |
|---|------|--|
| 2 | Misc | Busted curbing has been removed. New curbing has been formed and dowel bars have been inserted. RP 8-27-21 |
|---|------|--|

**Comments:**