

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210737
Address: 300 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Robb Popp	Passed	Friday, August 27, 2021

Informational:

1	Miscellaneous Correction	-Bonding for shell, (4) points, perimeter surface, ladder and handrail sleeves to equipment pad. -WATER BOND AT PUMP
---	--------------------------	---

Comments: