

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212678

Address: 32 SE 3RD ST, LEES SUMMIT, MO 64063 224 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Not Ready	Friday, August 27, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide boca plate DWV Fire caulk upward penetrations
---	-----------------------------	--

Comments: