

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20210263  
Address: 520 NW HOPE LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	Michael Harkins	Partial	Monday, August 30, 2021

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	- 20' CONDUIT FOOTING TOWARD ELECTRICAL ROOM - - CONDUIT MIDDLE OF SLAB TO ELECTRICAL ROOM - - CONDUIT STAIR TOWER & ELEVATOR EQUIPMENT ROOM TO ELECTRICAL ROOM -
---	----------------------------------	---

**Comments:**