

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20211516  
Address: 2350 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Monday, August 30, 2021

Informational:

1 Misc

**\*\*7/16/21 - GARAGE PORTAL EXTERIOR OK TO COVER\*\***

Corrective Action Required:

2 Miscellaneous  
Correction

-Interior Load bearing walls with top plates bored greater than 50% require structural straps on both sides of wall-straps to extend 6" past opening each direction  
-Address joist with holes bored closer than 2" in basement furnace intake/exhaust lines,garage pex lines  
-Anchor steel columns basement

**Comments:**