CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE PROSECUTED

Permit #: PRRES20213070

Address: 4817 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection: Outcome: Date:

Erosion Control Khanh Nguyen Failed - Stop Work Monday, August 30, 2021

Corrective Action Required

1 Misc 8/19/21 NL - Silt Fence needs to be cleaned up and re-installed.

Silt and rock needs to be removed from the street. Pictures

attached!

Corrective Action Required

2 Misc 8/25/21 NL - Silt Fence needs to be cleaned up and re-installed.

Silt and rock needs to be removed from the street. Pictures

attached from the first visit, waited a week still issues. Will give it

another week, please fix.

Comments: