

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202812
Address: 3209 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Tuesday, August 31, 2021

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">-Provide erosion control at perimeter of lot before any further inspections-Driveway and sidewalk inspections still pending-As graded plot plan required to be submitted and approved-Final grade and sod-Downspouts, gutters, splash blocks, sump extension-Clean debris from window wells-Seal top of meter can, ac disconnects and all exterior penetrations-Complete plumbing at kitchen sink-Complete hood installation at kitchen-Secondary lock required at both sliding glass doors-Fireblock storage room in basement joists from adjacent spaces-Lockout at range breaker-Set non combustible attic access panel-Flood light required at back of house per security code |
|---|------|---|

Comments: