

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212771
Address: 4408 SW LODESTONE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, August 31, 2021

Corrective Action Required:

1	Misc	-SMOKE/CO DETECTOR REQUIRED OUTSIDE OF BEDROOM -AFCI PROTECTION AT BASEMENT CIRCUIT LOCATIONS PER CODE E3902.16, NEC 210.12(A)
---	------	---

Comments: