

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210744
Address: 2155 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|----------|--------------------------|
| All Rough Inspection - Residential | Michael Harkins | Failed | Tuesday, August 31, 2021 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 2 | Miscellaneous Correction | No Deck pier inspection post not centered on piers (3rd party for 43 drilled piers for footings no deck piers) Plans show full height post center of covered deck Address rafters landing on multiple blocks Seal fire blocking dead spaces family room |
|---|--------------------------|--|

Comments: