

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210467
Address: 2049 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Tuesday, August 31, 2021

Corrective Action Required:

1	Misc	- PFH portaL frame approved - rear deck approved -covered front porch approved
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	Provide one roof vent per plan covered deck Nail abutting studs at intersecting wall corners per plan Provide through bolts deck beam to post connection : (2) 1/2 diameter through bolt or approved equivalent connector per 2018 IRC figure R507.5.1 (2)
---	--------------------------	---

Comments: