

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204751
Address: 2017 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, August 31, 2021

Corrective Action Required:

1	Miscellaneous Correction	Submit back flow certification lawn irrigation Sidewalk inspection pending Provide final grade Remove Constructiion debris from lot Provide sod & splash blocks Sump shall discharges 36" from foundation Guards shall not have openings that allow passage of a sphere 4" in diameter No deck pier inspection on record for covered deck (revised plan calls for pier L to be 28" diameter x 36" depth measured 18" diameter last week before patio slab poured)
---	--------------------------	--

Comments: