

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210101
Address: 329 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Michael Harkins	Failed	Wednesday, September 01, 2021

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE DECK PIERS PER PLAN (2) PIER K 24" X 36" (1) PIER J 18" X 36" PUMP WATER FROM PIERS
---	-----------------------------	--

Comments: