CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20211078

Address: 1450 NE DOUGLAS ST, LEES SUMMIT, MO 640861460 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Sanitary Sewer Construction Joe Starlin Partial Wednesday,

Inspection September 01, 2021

Informational:

1 Misc 9/1/21 Wednesday

Contractor installed 8" sanitary main approximately 41' and MH (C-7). Existing 6" sanitary line was verified as a wye & 45 degree bend around existing MH (S). Existing 6" sanitary line was concrete and and the new 8" sanitary was installed over it. The newly installed 8" sanitary ran under the existing water

line with 18" of clearance.

Comments: