



Update MBOE  
September 1, 2021  
Lot 146, Monticello 4<sup>th</sup> Plat

To Whom it May Concern

The Master Drainage Plan for Monticello 4<sup>th</sup> Plat calls out MBOE Right as 933.15 and MBOE Left as 935.00. The builder has provided a plot plan that illustrates a berm of 934.8 Left and 933.2 Right, with the installation of that berm to that height the MBOE for this lot can be removed. If you have any questions or need anything else please feel free to give me a call at (816) 623-9888.

Thank You

Matthew J. Schlicht, PE  
PE-2006019708





Update MBOE  
September 1, 2021  
Lot 145, Monticello 4<sup>th</sup> Plat

To Whom it May Concern

The Master Drainage Plan for Monticello 4<sup>th</sup> Plat calls out MBOE Right as 935.65 and MBOE Left as 933.15. The builder has provided a plot plan that illustrates a berm of 933.2 Left and 934.7 Right, with the installation of that berm to that height the MBOE for this lot can be removed. If you have any questions or need anything else please feel free to give me a call at (816) 623-9888.

Thank You

Matthew J. Schlicht, PE  
PE-2006019708

