CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202276

Address: 4712 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Piers/Caissons Inspection - Khanh Nguyen Failed Thursday, September

Residential 02, 2021

Corrective Action Required:

1 Misc PIERS ALREADY POURED AND NOT INSPECTED BY CITY. HAVE ENGINEER

APPROVE THEM

Comments: