

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211961
Address: 1523 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, September 02, 2021

Corrective Action Required:

1	Misc	-COMPLETE GAS LINE INSTALL AT FIREPLACE, PRESSURIZE LINE AFTER INSTALL FOR PRESSURE TEST, SECURE WARD FLEX GAS LINE AT FIREPLACE
---	------	--

Comments: