

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210506
Address: 1713 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Thursday, September 02, 2021

Corrective Action Required:

1	Miscellaneous Correction	*9-2-21 Garage portal inspection: -Provide (2) rows 16d sinkers 3" o.c. at top plate to header connection -Exterior ok to cover
---	--------------------------	--

Comments: