

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204748  
Address: 1516 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector:         | Outcome: | Date:                        |
|---------------------------------------------|--------------------|----------|------------------------------|
| <b>Gas Service Inspection - Residential</b> | Patrick Schonfeldt | Failed   | Thursday, September 02, 2021 |

Corrective Action Required:  
1      Misc      GAUGE AT 2 PSI, MUST MAINTAIN 10 PSI FOR 15 MINUTES FOR TEST

**Comments:**