



PLAN REVIEW CONDITIONS

September 02, 2021

Julia Hoban
589 W Nationwide Blvd, Suite B
Columbus, OH 43215

Permit No: PRCOM20214597
Project Title: CHIPOTLE DRIVE-THRU AND PICKUP
Project Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081
Parcel Number: 62140073000000000
Location: PIZZA HUT ADDITION LOT 1
Type of Work: NEW TENANT FINISH
Occupancy Group:
Description: TENANT FINISH FOR DRIVE-THRU AND PICKUP RESTAURANT

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

(Verified At Inspection)

Post occupant load sign at 49.

2. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing on the Type 1 Hood and duct detectors.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.