

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20200866
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|---------------|----------|------------------------------|
| Water Line - Hydrostatic Test | Nick Lightner | Passed | Thursday, September 02, 2021 |

Informational:

| | | |
|---|------|--|
| 1 | Misc | 9/2/21 8:30 - Started testing on 8" line at 8:30 on hydrant STA 5+61.66 sitting at 150 psi = PASSED 11:15 - Started testing on 6" line on hydrant 3+95.83 sitting at 150 psi = PASSED Plan to walk the water and sanitary laterals with the locator next week. |
|---|------|--|

Comments: