

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211430  
Address: 134 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Friday, September 03, 2021

Corrective Action Required:

1	Miscellaneous Correction	: PFH PORTAL FRAME ONLY : 5/8 ANCHOR BOLTS SHALL LAMD IN MIDDLE 1/3 THE WIDTH OF PLATE OVER NOTCHED STUDS AT 5/8 ANCHOR BOLTS
---	--------------------------	---

**Comments:**