

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20213593
Address: 2143 NW KILLARNEY LN, LEES SUMMIT, MO 64081

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Michael Harkins	Failed - Stop Work	Friday, September 03, 2021

Corrective Action Required

- | | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | - PROVIDE ADDRESS -
- COMPLETE INTERIOR DRAIN TILE -
- NO FOOTING INSPECTION ON RECORD -

- PROVIDE 3RD PARTY FOOTING INSPECTION WITHIN 48 HOURS
OF POUR - |
|---|--------------------------|---|

Comments: