

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210556
Address: 326 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, September 03, 2021

Corrective Action Required:

1	Misc	NO ACCESS, NO LOCKBOX CODE, LOCKED UP, NO PFH PORTAL FRAME INSPECTION Michael Harkins 09/03/2021 8:40 AM
---	------	--

Comments: