

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204069
Address: 3222 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Friday, September 03, 2021

Corrective Action Required:

1	Miscellaneous Correction	*9-3-21 INSPECITON DENIED -No address -No erosion control -Provide erosion control at perimeter of lot and maintain until sod is in place. Clean mud and debris from sidewalk, street and storm inlet. Protect street and sidewalks. No further inspections will be performed until in compliance
---	-----------------------------	--

Comments: