

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211510
Address: 2362 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Friday, September 03, 2021

Corrective Action Required:

1	Misc	*8-31-21 Portal frame inspection: -MIN. (2) 1/2" DIAMETER ANCHOR BOLTS INSTALLED PER R403.1.6 WITH 2"x2"x3/16" PLATE WASHER -FASTEN TOP PLATE TO HEADER WITH TWO ROWS OF 16d SINKER NAILS AT 3" O.C. -EXTERIOR ONLY OK TO COVER
---	------	--

Comments: