

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202669  
Address: 2330 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Failed	Tuesday, September 07, 2021

**Corrective Action Required:**

1	Misc	-Provide erosion control at perimeter until sod is in place, clean mud from sidewalks, protect street and sidewalk. No further inspections until in compliance -Final grade and sod, splash blocks -Seal top of meter can, AC disconnect and all exterior penetrations -Clean debris from window well -Install stop at front sidelight windows -Patch holes in rock at garage/ dwelling separation -Anchor steel column base -Patch rock at dining room receptacle under window -Replace broken ring at water meter pit
---	------	---

**Comments:**