CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20210156

Address: 2042 NW OBRIEN RD, LEES SUMMIT, MO 64081

Inspected On: Tuesday, September 07, 2021

Inspected By: Michael Harkins

Expiration Date: 9/30/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - Michael Harkins Temporary C of O Tuesday, September

Codes Residential 07, 2021

Corrective Action Required:

1 Miscellaneous Sidewalk inspection pending

Correction Driveway inspection pending

Sod & splash blocks

Provide guardrail front stoop over 30" to grade Sump shall discharge 36" from foundation wall