

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202276
Address: 4712 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, September 07, 2021

Corrective Action Required:

1	Misc	-Provide min 6" clearance from same window trim to grade
		-Anchor rear patio roof support walls to floor
		-Fb floor penetration at tub trap above service panel
		-Have engineer address misplaced I beam support column behind wet bar. Provide support pad below column

Comments: