#### CITY OF LEE'S SUMMIT

# Development Services Department 220 SE Green Street Lee's Summit, MO 64063

(816)969-1200

### **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20202637

Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Storm Sewer Construction Tom Taylor Partial Tuesday, September

Inspection 07, 2021

Informational:

1 Misc On Monday, 3-22-2021. She Diggs it resumed storm sewer installation on line

E. Contractor installed 117LF of 36" HDPE pipe and placed CI structure E3.

Contractor poured concrete inverts for structures E2 and E3.

Partial Correction:

2 PW-Storm Sewer

Inspection

Informational:

3 Misc Installed pipe and end section for detention basin in the back of property.

Installed storm pipe on line E.

Informational:

4 Misc Installing f-3 stormbox and HDPE pipe.on f line.

Informational:

5 Misc Waiting on truck to deliver more HDPE pipe. They are continuing work on

f-line box F-3.

Informational:

6 Misc Waiting on truck to deliver more HDPE pipe. They are continuing work on

f-line box F-3.

Informational:

7 Misc Waiting on HDPE pipe ton be delivered . Installing boxnF-4

Informational:

8 Miscellaneous Installing storm pipe along Bailey Rd. Stom pipe is leading to the east

Correction detention basin. Also installing the boxes. This was done on 4/12, 4/13 and

4/14.

Informational:

9 Misc Today they were tying in by the retention wall on Bailey. The contactors have

been installing A-line, they are pouring the inverts in the boxes that have

been installed.

Informational:

10 Misc On Monday 5-10-2021 thru Wednesday 5-12-2021, She Diggs it installed line E,

structures E5 thru E7. approx 250LF of 24" HDPE pipe was also installed and

back filled.

On Tuesday, 9-07-2021. She Diggs it resumed Storm sewer installation placing 15" HDPE pipe and neo-plastic structure MI. Contractor also installed approx

120LF of pipe.

#### **Comments:**