

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201877

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Nick Lightner	Partial	Tuesday, September 07, 2021

Informational:

1 Misc

Common Ground and ADA Ramps

9/7/21 10:45 - The sidewalks on Jamestown was poured when we arrived on site, spoke to contractor and he told me they are under 1.5% for slope. Did another inspection for the 35 ft on Freehold Dr, and spoke with the contractor about the ADA ramps on Freehold Dr and Jamestown.

14:30 - Sidewalk is ada compliant, told the contractor to fix a minor issue on the SW corner ramp was reading 8.6% told him to drop it down to 8.3%.

Comments: