

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204436
Address: 1508 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, September 08, 2021

Corrective Action Required:

1	Misc	TCO until 9-22-21 -Final driveway and sidewalk inspections required, contact development services to schedule -Secure sump discharge-heel and discharge line 7" above grade, not supported -1/2" through bolts required at deck post to beam connections- currently not 1/2" and not tight
---	------	---

Comments: