

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204976  
Address: 2910 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:         | Outcome: | Date:                            |
|-------------------------------------------------|--------------------|----------|----------------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Patrick Schonfeldt | Failed   | Wednesday,<br>September 08, 2021 |

Corrective Action Required:

|   |      |                                                                                                                                                                  |
|---|------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -support sump pump discharge, heel and discharge line above grade<br>-Uncover manhole MH21 as shown on plot plan at front of lot and raise to grade if necessary |
|---|------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**