

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211858
Address: 111 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, September 08, 2021

Corrective Action Required:

1	Miscellaneous Correction	: PFH PORTAL FRAME ONLY : - 5/8 ANCHOR BOLTS SHALL BE IN MIDDLE 1/3 THE WIDTH OF PLATE - CHECK ABOVE ON ALL ROUGH OK TO COVER EXTERIOR AT PFH PORTAL
---	-----------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: